

[Print](#)[Close](#)

---

## RE: Pool Issue?

---

From: **Ed Delahanty** (whshed@live.com)

Sent: Mon 7/28/14 10:19 AM

To: Dustin Frederick (dustin@local519.org); Steve Morrow (stevem@marketpacers.com); chris hendrickson (hendrickcj@gmail.com); Fred Salmon (pheffy@aol.com); Kurt S. Blankenship (kblankenship@bluewilliams.com); Suzy Palmer (suzypalmer1@me.com)

Carol, Fred & Suzy are mutually aware of the issues that need attention and will be following up while I'm away this week (returning no later than Sunday). We're in contact with pool professionals to take care of the issues requiring their attention. I'll call the State DOH today to see if there are any issues with the waiver request.

Ed.

---

From: dustin@local519.org

To: whshed@live.com; stevem@marketpacers.com; hendrickcj@gmail.com; pheffy@aol.com; kblankenship@bluewilliams.com; suzypalmer1@me.com

Subject: RE: Pool Issue?

Date: Mon, 28 Jul 2014 13:43:05 +0000

Sorry----I misunderstood----thought we were closer. My additional two cents---I think we need to open---if it is only for a week or two for a host of other reasons.

Do you have someone scheduled to work on the deck issues i.e. pool tiles light cavities etc?

Dustin

---

**From:** Ed Delahanty [mailto:whshed@live.com]

**Sent:** Sunday, July 27, 2014 10:42 PM

**To:** Dustin Frederick; Steve Morrow; chris hendrickson; Fred Salmon; Kurt S. Blankenship; Suzy Palmer

**Subject:** RE: Pool Issue?

Not quite, we still need to get a waiver approved by the State DOH people - info waiting in their in box for Monday am. Also need some work done on the chemical dispensing equipment and some repairs remaining to be done on the deck, pool tiles, covers over two empty lights cavities in the pool and we're

still struggling with the Stratum VRS device which we need functional to be compliant with the Virginia Graeme Baker Act and hopefully the waiver mentioned above. Fred & I've done our best to analyze the Stratum VRS and now are waiting for contact from a regional expert on the system to help trouble shoot the device.

Many volunteers under Suzy and Carol's guidance have worked miracles on getting the facility looking good. Trina Trimmer's been doing her best to keep the pool water in good condition - a struggle when we couldn't keep the pump running for a week and a half. Fred and to a smaller extent I have spent quite a bit of time working with contractors and each other to get things up and running and legally compliant. I'd guess that Fred's spent at least 25 hours a week on the pool, maybe quite a bit more. As I stated at our June Board meeting, no guarantee on how long it would take or if we'd actually be able to open.

A little patience please.

Ed.

---

From: [dustin@local519.org](mailto:dustin@local519.org)

To: [whshed@live.com](mailto:whshed@live.com); [stevem@marketpacers.com](mailto:stevem@marketpacers.com); [hendrickcj@gmail.com](mailto:hendrickcj@gmail.com); [pheffy@aol.com](mailto:pheffy@aol.com); [kblankenship@bluewilliams.com](mailto:kblankenship@bluewilliams.com); [suzypalmer1@me.com](mailto:suzypalmer1@me.com)

Subject: RE: Pool Issue?

Date: Mon, 28 Jul 2014 03:56:53 +0000

Hi All----anybody know when the pool is going to open---I thought it was this weekend. I got the minutes out on Monday for the health Dept---I thought that was the last item.

I went up this weekend thinking it was going to be open---but no dice.

What are we waiting for?

Dustin

---

**From:** Ed Delahanty [<mailto:whshed@live.com>]

**Sent:** Friday, July 25, 2014 10:27 PM

**To:** Steve Morrow; chris hendrickson; Dustin Frederick; Fred Salmon; Kurt S. Blankenship; Suzy Palmer

**Subject:** RE: Pool Issue?

The incorrect wiring was corrected in 2012 by a certified electrician when the Hayward Stratum VRS device was "moved". This occurred during the time Alex Greco was managing and maintaining the pool in July of 2012.

The Stratum VRS will have to function correctly before we can allow swimmers in the pool. We have a call in to a local pool company authorized to work on Hayward products to assist us in verifying the device works correctly. At the moment it is over sensitive which contributes significantly to the problems we've

had getting the pump running regularly.

Not sure how most effectively to answer Jean except to say that the pool will not open unless the Stratum VRS device is working correctly.

Ed.

---

From: [stevem@marketpacers.com](mailto:stevem@marketpacers.com)

To: [hendrickcj@gmail.com](mailto:hendrickcj@gmail.com); [dustin@local519.org](mailto:dustin@local519.org); [whshed@live.com](mailto:whshed@live.com); [pheffy@aol.com](mailto:pheffy@aol.com); [kblankenship@bluewilliams.com](mailto:kblankenship@bluewilliams.com); [suzypalmer1@me.com](mailto:suzypalmer1@me.com)

Subject: Pool Issue?

Date: Fri, 25 Jul 2014 17:26:36 -0700

Ed:

Is there any substance to a requirement for specific action vetting the VGB device?

Unlike Maria's posts, this sounds like a reasonable statement of history.

---

**From:** [reply@r.email.nextdoor.com](mailto:reply@r.email.nextdoor.com) [<mailto:reply@r.email.nextdoor.com>]

**Sent:** Friday, July 25, 2014 9:58 AM

**To:** [stevem@marketpacers.com](mailto:stevem@marketpacers.com)

**Subject:** Re: WARNING - SERIOUS SAFETY POOL ISSUES.REMAINING



Jean Salls, [Admiral's Cove Beach Club](#)

@ Bob Wilbur

Some ACBC members are concerned about safe operations of the pool. We want our neighbors and families to swim in safe conditions. In 2012 while repairing a recalled drain cover, it was discovered that the automatic shut-off equipment had been illegally installed. The electrician who placed his name on the device after installation claimed that he only "made it work" after volunteers had installed it. He claimed he did this as a favor to a Board Member. This illegal installation was tagged by the Washington State Electrical Inspector checking on a major rewiring project. It was moved and worked during the short swim season in 2012. Now apparently, efforts have been made unsuccessfully by volunteers to re-calibrate this vital piece of equipment that has failed repeatedly in the past.

Failure of this type of equipment has resulted in serious injury and death to children and adults nationwide and has caused millions of dollars in claims litigation and wrongful death awards. It seems only reasonable to have a community member present when testing by professionals takes place.

All this effort will not be necessary if refurbishment and dual drains are installed. Wouldn't it have been wise to wait to operate when all safety concerns are addressed? Meanwhile my family enjoys the pool at Camp Casey that is professionally managed and meets all Federal and State codes.

Jean Salls

Original post by [Russell and Maria Chamberlain](#) from [Admiral's Cove Beach Club](#) (23 replies):

One important issue than, it has not been disclose, about Wednesday visits, is the Washington State INDUSTRIAL INSURANCE INSPECTOR, five items were Red tagged, on the heating devise (or boiler). ...

Jul 18 in [General](#) to [your neighborhood](#)

[View or reply](#)

[Thank](#) · [Private message](#)

You can also reply to this email or use Nextdoor for [iPhone](#) or [Android](#)

---

You received this email because you thanked/replied to this post. Not interested in future updates? [Stop receiving immediate updates on this post](#)

This message is intended for [stevem@marketpacers.com](mailto:stevem@marketpacers.com).  
[Unsubscribe or adjust your email settings](#)

[Nextdoor, Inc. 760 Market St., Suite 300, San Francisco, CA 94102](#)