

[Print](#)[Close](#)

RE: pool dimensions

From: **Ed Delahanty** (whshed@live.com)
Sent: Wed 2/06/13 2:52 PM
To: Sue Corliss (cedars@olyphen.com)

Hi Sue,

My recollection of a potential depth change is that only the deep end would be effected, the shallow end would stay at it's current 3feet. Your estimate of the deep end potential change is more or less the same as mine.

I have a concern with reducing the depth of the deep end, will send a memo summarizing my concern to the Pool Maint & Improvement committee members soon.

Kind Regards,
Ed.

From: cedars@olyphen.com
Subject: Re: pool dimensions
Date: Mon, 4 Feb 2013 22:49:15 -0800
To: whshed@live.com

Thank you Ed. I really appreciate this, I will indicate that the depth is approximately 2'6" shallow end and 7-8' in deep end (about what restoration MAY be).

Thank you again
Sue Corliss
360 678 3731
cedars@olyphen.com

On Feb 4, 2013, at 8:09 PM, Ed Delahanty wrote:

Hi Sue,

Surface area of the pool is 2,230 square feet. (this is length times width, including the two enlarged areas at the shallow and deep ends)

For planning purposes, volume of the pool is 100,000 gallons. The depth varies from the shallow end to the deep end.

We should have circulation of around 300 gallons per minute (gpm) to meet the Health Department requirements giving a complete exchange of water in 6 hours or less. 10 % more would be nice. Current equipment is below that rate.

Let me know if you have any further questions.

Kind Regards,
Ed.

> To: whshed@live.com; karensaak@gmail.com
> From: cedars@olyphen.com

> Subject: pool dimensions
> Date: Mon, 4 Feb 2013 10:26:48 -0800
>
> Hi
>
> I need some information and I hope you can help me. I need the size
> of the pool(length, width& depth) and the gallons per minute that
> circulates the water through the system.
>
> Cathie thought maybe one of you would know this.
>
> Thank you
> Sue Corliss
> 360 678 3731
> cedars@olypen.com
>