

[Print](#)[Close](#)

RE: Admiral's Cove Pool

From: **Adam Hudson** (adamh@newconceptchem.com)
Sent: Fri 7/25/14 1:33 PM
To: 'Ed Delahanty' (whshed@live.com)
2 attachments
credit app 1.jpeg (233.3 KB) , credit app 2.jpeg (252.0 KB)

Ed,

Id be happy to help with your Polaris issue. What symptoms/ problems is your unit currently having?

In regards to the low water protection being an issue with the DOH, there is not much I can do as far as convincing the DOH that you don't need it. The code they are enforcing is not something that they typically have a problem with, but that being said, if they want you to comply, it is easiest to find a cost effective way to do so. If you need a wireless auto fill device, it would run around \$1000 to get one installed on your system. If you need an official quote for that potential job, let me know. Also, I have attached a credit application so that we can more easily do business in the future.

Thanks,

Adam Hudson

Account Manager

Cesco New Concept Products

360-734-4631

From: Ed Delahanty [mailto:whshed@live.com]
Sent: Thursday, July 24, 2014 5:39 PM
To: adamh@newconceptchem.com
Cc: Fred Salmon
Subject: Admiral's Cove Pool

Hi Adam,

I'd like a follow up conversation with you regarding what work your company is considering taking on with our pool this year.

We all appreciate the effort you and your colleague put in last week trouble shooting the pump priming issue, the system will run for a number of hours now before the Hayward VRS shuts it down. We'll see if we can get another source to trouble shoot that but would like to know if you can take on getting the Polaris Watermatic functioning correctly with the chlorinator and muriatic acid dispenser, which would include replacing the small gauge lines running from the outflow main lines to the sampler.

Fred Salmon also mentioned that you might be able to get in touch with the Washington State DOH folks on the issue with the low water sensor. Had any luck there?

Please call if we need to discuss.

Kind Regards,

Ed Delahanty

360 969 2205